



Product Service

CERTIFICATE

No. B 09 10 71686 001

Holder of Certificate: COLCOM Srl
Via degli Artigiani 56
27075 NAVE (BS)
ITALY

Certification Mark:



Product: Door Fittings
(Hinges)

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: MEC 09061.00

Date, 2009-10-16

Page 1 of 2

Angelo Polizzi





CERTIFICATE

No. B 09 10 71686 001

Model(s):

**BILOBA 8010, BILOBA 8011, BILOBA 8015,
BILOBA 8060, TRILOBA 8201/8202**

Parameters:

Product	Efficiency [%]	Range [°]
BILOBA 8010	92	0°; +90°; -90°
BILOBA 8011	92	0°; +90°; -90°
BILOBA 8015	92	0°; +90°; -90°
BILOBA 8060	93	0°; +90°
TRILOBA 8201/8202	94	0°; +90°; -90°

Load max: 150 kg for model TRILOBA 8201/8202
100 kg for the other models

Material: Alloy 6060, Alloy AB 44100,
Inox AISI 303, Steel 42CrMo

Tested according to:

EN 1154:2006

Production Facility(ies):

71686

AP



Product Service